



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Götessons, Akustikmiljö / Am Acoustics
Object:	Vertikal
Size [mm]:	w=130 h=2400 d=3000 Total Construction Height=35.00

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.40
125	1.10
250	2.80
500	3.80
1000	3.70
2000	4.60
4000	5.50

N₁₀ = 2.7

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
16-239-M20	2016-12-14

