



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Akustikmiljö / Am Acoustics
Object:	Single
Size [mm]:	w=50 h=3000 d=1500

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.40
125	1.20
250	2.60
500	4.10
1000	4.60
2000	4.40
4000	4.70

N₁₀ = 2.4

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

