



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Akustikmiljö / Am Acoustics
Object:	Lätt
Size [mm]:	w=50 h=1200 d=600

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.00
125	0.20
250	0.60
500	1.40
1000	1.30
2000	1.10
4000	1.10

N₁₀ = 9.1

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

