



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Akustikmiljö / Am Acoustics
<b>Object:</b>	Lätt
<b>Size [mm]:</b>	w=50 h=1200 d=600

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.00
125	0.20
250	0.60
500	1.40
1000	1.30
2000	1.10
4000	1.10

N<sub>10</sub> = 9.1

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

