



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


| | |
|-------------------|--|
| Producer: | Götessons, Akustikmiljö / Am Acoustics |
| Object: | Lod |
| Size [mm]: | w=50 h=2400 d=3000 |

Equivalent sound absorption area per unit (m² Sabine)

| f(Hz) | Octave Band |
|-------|-------------|
| 63 | 0.40 |
| 125 | 1.00 |
| 250 | 2.40 |
| 500 | 4.10 |
| 1000 | 4.80 |
| 2000 | 4.60 |
| 4000 | 5.30 |

N₁₀ = 2.4

Equivalent sound absorption area per unit



| | |
|-----------------------------|-----------------------|
| ORIGINAL TEST REPORT | DATE OF REPORT |
| - | - |

