



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Götessons, Akustikmiljö / Am Acoustics
Object:	Lod
Size [mm]:	w=50 h=2400 d=3000

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.40
125	1.00
250	2.40
500	4.10
1000	4.80
2000	4.60
4000	5.30

N₁₀ = 2.4

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

