



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Götessons, Akustikmiljö / Am Acoustics
Object:	Effekt
Size [mm]:	w=50 h=300 d=1200

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.10
125	0.20
250	0.50
500	0.70
1000	0.80
2000	0.80
4000	0.80

N₁₀ = 14

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
16-239-M10	2016-12-02

