PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Götessons
Object:	ScreenIT A30 W. built in Rail
Size [mm]:	w=40 h=650 d=2000

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.20
125	0.50
250	0.80
500	1.10
1000	1.40
2000	1.60
4000	1.80

N_{10} = 9.1



ORIGINAL TEST REPORT	DATE OF REPORT
-	-