



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Glimakra Of Sweden
Object:	Limbus Floor Screen
Size [mm]:	w=40 h=1200 d=1500

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.00
125	0.20
250	0.60
500	1.40
1000	2.60
2000	3.10
4000	2.80

N₁₀ = 7.1

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
WSP Acoustics report 10171560.04	2012-01-30

