PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Glimakra Of Sweden
Object:	Webb Floor Screen
Size [mm]:	w=40 h=1000 d=1600

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.00
125	0.00
250	0.40
500	1.00
1000	2.30
2000	2.60
4000	2.60

N_{10} = 10



ORIGINAL TEST REPORT	DATE OF REPORT
-	-