



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Abstracta
Object:	Bits Wall 30 pcs
Size [mm]:	w=95 h=3060 d=2320

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.00
125	1.10
250	2.70
500	4.00
1000	4.20
2000	4.20
4000	4.00

N₁₀ = 2.5

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
1370-001-12	2013-09-11

