



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


| | |
|-------------------|--------------------|
| Producer: | Abstracta |
| Object: | Bits Wall 30 pcs |
| Size [mm]: | w=95 h=3060 d=2320 |

Equivalent sound absorption area per unit (m² Sabine)

| f(Hz) | Octave Band |
|-------|-------------|
| 63 | 0.00 |
| 125 | 1.10 |
| 250 | 2.70 |
| 500 | 4.00 |
| 1000 | 4.20 |
| 2000 | 4.20 |
| 4000 | 4.00 |

N₁₀ = 2.5

Equivalent sound absorption area per unit



| | |
|-----------------------------|-----------------------|
| ORIGINAL TEST REPORT | DATE OF REPORT |
| 1370-001-12 | 2013-09-11 |

