



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


| | |
|-------------------|--------------------|
| Producer: | Abstracta |
| Object: | Alumi |
| Size [mm]: | w=63 h=1506 d=1206 |

Equivalent sound absorption area per unit (m² Sabine)

| f(Hz) | Octave Band |
|-------|-------------|
| 63 | 0.40 |
| 125 | 0.90 |
| 250 | 2.00 |
| 500 | 2.70 |
| 1000 | 2.90 |
| 2000 | 2.90 |
| 4000 | 2.90 |

N₁₀ = 3.7

Equivalent sound absorption area per unit



| | |
|-----------------------------|-----------------------|
| ORIGINAL TEST REPORT | DATE OF REPORT |
| - | - |

