PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Abstracta
Object:	Airflake Line Closed
Size [mm]:	w=20 h=720 d=2000 Total Construction Height=100

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.000
125	0.000
250	0.100
500	0.700
1000	1.000
2000	0.800
4000	0.900

N_{10} = 14



ORIGINAL TEST REPORT	DATE OF REPORT
P702033-E	2013-08-19