



# PRODUCT DECLARATION

## SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Abstracta
<b>Object:</b>	Airflake Line Closed
<b>Size [mm]:</b>	w=20 h=720 d=2000 Total Construction Height=100

### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.00
125	0.00
250	0.10
500	0.70
1000	1.00
2000	0.80
4000	0.90

N<sub>10</sub> = 14

### Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

