



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Glimakra Of Sweden
Object:	Alp Large
Size [mm]:	w=461 h=1800 d=1180

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.00
125	0.30
250	0.80
500	1.80
1000	3.40
2000	3.90
4000	4.10

N₁₀ = 5.6

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
WSP Acoustics report 10171560.01	2012-01-30

