



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Abstracta
Object:	Airflake Blade Open
Size [mm]:	w=20 h=720 d=2000 Total Construction Height=100

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.00
125	0.00
250	0.00
500	0.10
1000	0.40
2000	0.50
4000	0.60

N₁₀ = 100

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

