PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Abstracta
Object:	Airflake Blade Open
Size [mm]:	w=20 h=720 d=2000 Total Construction Height=100

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.000
125	0.000
250	0.000
500	0.100
1000	0.400
2000	0.500
4000	0.600

N_{10} = 100



ORIGINAL TEST REPORT	DATE OF REPORT
P702033-E	2013-08-19

Acoustic Facts Scandinavia AB
Kinnegatan 23, 531 33 Lidköping