



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Abstracta
<b>Object:</b>	Airflake Blade Open
<b>Size [mm]:</b>	w=20 h=720 d=2000 Total Construction Height=100

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.00
125	0.00
250	0.00
500	0.10
1000	0.40
2000	0.50
4000	0.60

N<sub>10</sub> = 100

#### Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

