PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Kinnarps
Object:	Oktav 96 6pcs
Size [mm]:	w=96 h=1100 d=1650 Total Construction Height=36

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.10
125	0.40
250	1.10
500	1.80
1000	2.00
2000	1.90
4000	1.90

N_{10} = 5.6



ORIGINAL TEST REPORT	DATE OF REPORT
-	-