



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Kinnarps
<b>Object:</b>	Oktav 60 6pcs
<b>Size [mm]:</b>	w=60 h=1100 d=1650

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.10
125	0.30
250	0.80
500	1.50
1000	1.90
2000	1.90
4000	1.80

N<sub>10</sub> = 6.7

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

