



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Offecct
Object:	Smallroom Sofa 1500
Size [mm]:	w=720 h=1340 d=1501

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	1.00
125	2.00
250	2.00
500	2.30
1000	2.60
2000	3.30
4000	4.20

N₁₀ = 4.3

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

