



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Kinnarps
Object:	Prim Hanging Screen 160x198
Size [mm]:	w=55 h=1980 d=1600

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.50
125	1.30
250	2.90
500	4.60
1000	5.60
2000	5.90
4000	5.70

N₁₀ = 2.2

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

