



# PRODUCT DECLARATION

## SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Blå Station
<b>Object:</b>	Ginkgo
<b>Size [mm]:</b>	w=60 h=420 d=500

### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.01
125	0.02
250	0.08
500	0.11
1000	0.10
2000	0.09
4000	0.09

N<sub>10</sub> = 110

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

