



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Blå Station
Object:	Ginkgo 30 pcs
Size [mm]:	w=60 h=1850 d=2000

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.20
125	0.60
250	2.30
500	3.40
1000	3.00
2000	2.80
4000	2.60

N₁₀ = 3.8

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

