



# PRODUCT DECLARATION

## SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Blå Station
<b>Object:</b>	Ginkgo 30 pcs
<b>Size [mm]:</b>	w=60 h=1850 d=2000

### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.20
125	0.60
250	2.30
500	3.40
1000	3.00
2000	2.80
4000	2.60

N<sub>10</sub> = 3.8

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

