



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Götessons
Object:	Sofa sound booth Freely
Size [mm]:	w=695 h=1400 d=1690

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	1.90
125	2.20
250	3.30
500	4.20
1000	4.60
2000	5.00
4000	5.40

N₁₀ = 2.4

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

