



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Offecct
Object:	Membrane
Size [mm]:	w=100 h=1614 d=1405

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.00
125	0.10
250	0.20
500	0.50
1000	1.10
2000	1.50
4000	1.60

N₁₀ = 20

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

