PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Offecct
Object:	Membrane
Size [mm]:	w=100 h=1614 d=1405

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.000
125	0.100
250	0.200
500	0.500
1000	1.100
2000	1.500
4000	1.600

N_{10} = 20



ORIGINAL TEST REPORT	DATE OF REPORT
-	-