



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Götessons
<b>Object:</b>	The Hut
<b>Size [mm]:</b>	w=1800 h=2270 d=1870

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	3.00
125	5.20
250	9.30
500	11.50
1000	12.70
2000	13.80
4000	14.80

N<sub>10</sub> = 0.87

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
5P08641-A/eng	2016-01-11

