



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Götessons
Object:	The Hut
Size [mm]:	w=1800 h=2270 d=1870

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	3.00
125	5.20
250	9.30
500	11.50
1000	12.70
2000	13.80
4000	14.80

N₁₀ = 0.87

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
5P08641-A/eng	2016-01-11

