PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Götessons
Object:	The Hut
Size [mm]:	w=1800 h=2270 d=1870

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	3.0
125	5.2
250	9.3
500	11.5
1000	12.7
2000	13.8
4000	14.8

N_{10} = 0.87



ORIGINAL TEST REPORT	DATE OF REPORT
5P08641-A/eng	2016-01-11