



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Götessons
Object:	ScreenIT AT40
Size [mm]:	w=40 h=650 d=1600

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.10
125	0.20
250	0.50
500	1.00
1000	1.40
2000	2.00
4000	2.50

N₁₀ = 10

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

