PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Götessons
Object:	ScreenIT A40
Size [mm]:	w=50 h=650 d=1600

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.33
125	0.67
250	1.00
500	1.30
1000	1.40
2000	1.53
4000	1.67

N_{10} = 7.7



ORIGINAL TEST REPORT	DATE OF REPORT
-	-