



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Glimakra Of Sweden
<b>Object:</b>	Wannabetree No. 4
<b>Size [mm]:</b>	w=560 h=1415 d=1070

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.03
125	0.16
250	0.42
500	0.84
1000	1.52
2000	1.80
4000	1.75

N<sub>10</sub> = 12

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

