



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Glimakra Of Sweden
Object:	Wannabetree No. 4
Size [mm]:	w=560 h=1415 d=1070

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.03
125	0.16
250	0.42
500	0.84
1000	1.52
2000	1.80
4000	1.75

N₁₀ = 12

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

