



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Götessons
Object:	Hang On
Size [mm]:	w=830 h=600 d=689

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.00
125	1.50
250	1.90
500	1.80
1000	1.60
2000	1.50
4000	1.40

N₁₀ = 7.1

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

