



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Abstracta
<b>Object:</b>	Stitch
<b>Size [mm]:</b>	w=80 h=1465 d=1000

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.40
125	0.80
250	1.70
500	2.50
1000	2.80
2000	3.00
4000	3.10

N<sub>10</sub> = 4

#### Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

