PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Abstracta
Object:	Stitch
Size [mm]:	w=80 h=1465 d=1000

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.40
125	0.80
250	1.70
500	2.50
1000	2.80
2000	3.00
4000	3.10

N_{10} = 4



ORIGINAL TEST REPORT	DATE OF REPORT
-	-