



# PRODUCT DECLARATION

## SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Kinnarps
<b>Object:</b>	Prim Floor Screen 160x200
<b>Size [mm]:</b>	w=55 h=2000 d=1600

### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.60
125	1.80
250	3.60
500	5.10
1000	6.00
2000	6.00
4000	6.30

N<sub>10</sub> = 2

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

