



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Kinnarps
Object:	Prim Floor Screen 160x200
Size [mm]:	w=55 h=2000 d=1600

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.60
125	1.80
250	3.60
500	5.10
1000	6.00
2000	6.00
4000	6.30

N₁₀ = 2

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

