



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Götessons
<b>Object:</b>	Sound Off Wall
<b>Size [mm]:</b>	w=50 h=1400 d=1400

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.07
125	0.42
250	0.90
500	1.41
1000	1.50
2000	1.48
4000	1.46

N<sub>10</sub> = 7.1

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
4P00541A/Eng	2014-03-17

