PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Götessons
Object:	Sound Off Wall
Size [mm]:	w=50 h=1400 d=1400

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.07
125	0.42
250	0.90
500	1.41
1000	1.50
2000	1.48
4000	1.46

N_{10} = 7.1



ORIGINAL TEST REPORT	DATE OF REPORT
4P00541A/Eng	2014-03-17