



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Blå Station
Object:	Gaia 8 pcs
Size [mm]:	w=90 h=1300 d=2600

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
63	0.10
125	0.20
250	1.00
500	2.30
1000	2.80
2000	2.90
4000	3.00

N₁₀ = 4.3

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

