



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Blå Station
<b>Object:</b>	Gaia 8 pcs
<b>Size [mm]:</b>	w=90 h=1300 d=2600

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
63	0.10
125	0.20
250	1.00
500	2.30
1000	2.80
2000	2.90
4000	3.00

N<sub>10</sub> = 4.3

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

