



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT


Mätt och utvärderad enligt ISO 354 och ISO 20189

Producent:	Abstracta
Objekt:	Abstracta Wall of Art
Storlek [mm]:	w=40 h=500 d=700

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
100	0.02	
125	0.00	0.08
160	0.13	
200	0.07	
250	0.13	0.12
315	0.17	
400	0.21	
500	0.24	0.22
630	0.21	
800	0.16	
1000	0.14	0.15
1250	0.14	
1600	0.13	
2000	0.12	0.12
2500	0.12	
3150	0.13	
4000	0.11	0.11
5000	0.08	

Ekvivalent ljudabsorptionsarea per objekt



N₁₀ = 94

ORIGINAL TESTRAPPORT

20230605.1

RAPPORTDATUM

2023-06-12

