



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT

Mätt och utvärderad enligt ISO 354 och ISO 20189


Producent:	Abstracta
Objekt:	Abstracta Agile
Storlek [mm]:	w=540 h=1359 d=1945

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
100	0.73	
125	1.02	1.00
160	1.28	
200	1.57	
250	1.89	1.70
315	1.70	
400	1.96	
500	2.01	1.90
630	1.72	
800	1.53	
1000	1.64	1.60
1250	1.64	
1600	1.56	
2000	1.60	1.50
2500	1.48	
3150	1.26	
4000	1.35	1.30
5000	1.15	

N₁₀ = 8

Ekvivalent ljudabsorptionsarea per objekt



ORIGINAL TESTRAPPORT	RAPPORTDATUM
20220105.4	2022-01-05

