



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT


Mätt och utvärderad enligt ISO 354 och ISO 20189

Producent:	Abstracta
Objekt:	Holly lighting, horizontal
Storlek [mm]:	w=540 h=585 d=1052

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
100	-0.08	
125	0.22	0.23
160	0.54	
200	0.70	
250	0.70	0.77
315	0.91	
400	1.05	
500	1.13	1.09
630	1.08	
800	0.91	
1000	0.91	0.92
1250	0.95	
1600	0.93	
2000	1.03	0.99
2500	0.99	
3150	1.06	
4000	1.06	1.05
5000	1.02	

Ekvivalent ljudabsorptionsarea per objekt



N₁₀ = 11

ORIGINAL TESTRAPPORT

RAPPORTDATUM

20220608.2

2023-04-20

