



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT

Mätt och utvärderad enligt ISO 354 och ISO 20189


| | |
|----------------------|--|
| Producent: | Abstracta |
| Objekt: | Holly lighting, vertical (corner position) |
| Storlek [mm]: | w=540 h=585 d=883 |

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

| f(Hz) | Tersband | Oktavband |
|-------|----------|-----------|
| 100 | 0.25 | |
| 125 | 0.60 | 0.42 |
| 160 | 0.41 | |
| 200 | 0.61 | |
| 250 | 0.59 | 0.64 |
| 315 | 0.73 | |
| 400 | 0.76 | |
| 500 | 0.85 | 0.84 |
| 630 | 0.91 | |
| 800 | 0.62 | |
| 1000 | 0.71 | 0.67 |
| 1250 | 0.67 | |
| 1600 | 0.73 | |
| 2000 | 0.73 | 0.73 |
| 2500 | 0.74 | |
| 3150 | 0.76 | |
| 4000 | 0.78 | 0.82 |
| 5000 | 0.92 | |

N₁₀ = 15

Ekvivalent ljudabsorptionsarea per objekt



| | |
|-----------------------------|---------------------|
| ORIGINAL TESTRAPPORT | RAPPORTDATUM |
| 20220608.2 | 2023-04-20 |

