



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT


Mätt och utvärderad enligt ISO 354 och ISO 20189

Producent:	Abstracta
Objekt:	Scala Floor
Storlek [mm]:	w=60 h=1600 d=1207

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
50	0.19	
63	0.28	0.30
80	0.31	
100	0.40	
125	0.47	0.50
160	0.68	
200	1.38	
250	1.26	1.40
315	1.50	
400	1.86	
500	2.05	2.10
630	2.33	
800	2.75	
1000	2.89	2.90
1250	3.16	
1600	3.29	
2000	3.36	3.40
2500	3.49	
3150	3.67	
4000	3.72	3.80
5000	3.96	

Ekvivalent ljudabsorptionsarea per objekt



$N_{10} = 4.8$

ORIGINAL TESTRAPPORT	RAPPORTDATUM
17-094-M8	2017-05-19

